

28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZ/


919

Dated: 30/8/22

FIRE SAFETY CERTIFICATE

Certified that the St. John's Academy located at Church Road, Jawala Nagar, Delhi-110032, building comprised basement, ground plus three upper floors (one block) & two blocks are ground plus two upper floor (all blocks are interconnected), owned/occupied by St. John's Academy has already been issued FSC vide letter no. F6/DFS/MS/School/2019/NDZ/1466 dated 17/07/19. The premises was re-inspected by the officer concerned of fire service on 16/08/2022 in the presence of Mr. Philip and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 30/8/22 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 30/8/22 at New Delhi by


(S.K. DUA)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

To.

The Principal
St. John's Academy located at Church Road, Jawala Nagar, Delhi-110032

Copy:-

The Dy. Director of Education,
D-Block, Anand Vihar, Delhi- 110092

Conditions for the validity of Fire Safety Certificate

1. Basement shall be used strictly as per building By-laws.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry