

**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DY. HEALTH OFFICER
SHAHDARA NORTH ZONE**

No. DHO/Shah (N)/2023/D-149


Dated: 11/5/23

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no. 352 dated 11.05.2023, the inspection of "ST. JOHN'S ACADEMY" at 54/VIII, Church Road Jwalanagar, Shahdara, Delhi-110032 was carried out on dated 11.05.2023. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

**Manager
ST. JOHN'S ACADEMY
54/VIII, Church Road Jwalanagar
Shahdara, Delhi-110032**


**Dy. Health Officer
Shahdara North Zone
Deputy Health Officer
Shahdara North Zone
Municipal Corporation of Delhi**

"STOP CORONA VIRUS-" "STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



NO: DJB/ACWA(TYR)/2022.....

DATE:- 22-10-2022

Analysis report of DJB supply water samples collected from (1) Inlet and (2) Outlet St. John, s
Academy Modern 54/VIII Church Road Jwalanagar Shahdara Delhi-32 for drinking Purpose.

Ref. No. SJN/EDN/32-2022

Challan No:-213

dated:- 17-10-2022

Date of collection:- 18-10-2022

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	1.44	1.03
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	341	348
6.	Total Dissolved Solids	500	2000	mg/l	221	226
B.	Chemical Examination					
7.	P th Alkalinity	45	NO RELAXATION	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	94	92
9.	Total Hardness	200	600	mg/l	128	130
10.	Calcium Hardness	mg/l	86	98
11.	Magnesium Hardness	mg/l	42	32
12.	Calcium as (Ca)	75	200	mg/l	34.4	39.2
13.	Magnesium as (Mg)	30	100	mg/l	10.08	7.68
14.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
15.	Nitrite	mg/l	N.D	N.D
16.	Nitrate	45	NO RELAXATION	mg/l	2.8	2.56
17.	Sulphate	200	400	mg/l	42.44	51.19
18.	Chloride	250	1000	mg/l	28	18
19.	Fluoride	1.0	1.5	mg/l	0.18	0.2
20.	Total Iron	1.0	NO RELAXATION	mg/l	0.08	0.08
21.	Cyanide	0.05	NO RELAXATION	mg/l	N.D	N.D
22.	Residual Chlorine	0.2	1.0	mg/l	0.25	0.20
C.	Bacteriological Examination					
23.	Coliform count	Absent	NO RELAXATION	MPN/ 100ml	0	0

This Report
Pertains To
The Particular
Sample Only

REMARKS:- On the basis of above tested parameters, water samples conforms BIS: 10500-2012 and be considered fit for drinking purpose.

CHEMIST

22/10/2022
CHEMIST

22-10-22
ACWA (TYR)
Asst. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tyr)
Tahir Pur Dilshad Garden, Delhi-93