

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/School/2025/NDZ/ 539

Dated: 24/04/2025

**FIRE SAFETY CERTIFICATE**

Certified that the St. John's Academy at 54/VIII, Church Road, Jawala Nagar, Shahdara, Delhi-110032, comprised of ground plus two floor only (two blocks) & basement ground plus three upper floors, owned/occupied by St. John's Academy was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/919 dated 30/08/2022. The school building was re-inspected by the officer concerned of this department on 16/04/2025 in the presence of Mr. Philp and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 24/04/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on... 24/04/2025 .....at New Delhi by.

  
ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

To,  
The Principal,  
St. John's Academy at 54/VIII, Church Road, Jawala Nagar, Shahdara, Delhi-110032.

Copy:-  
The Dy. Director of Education,  
D-Block, Anand Vihar, Delhi-110053

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The basement is used as storage purpose only.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.