




No.DJB/QCLTYR/PD/2501109

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015



एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2025.....

DATE:- 26-11-2025

Analysis report of DJB water supply samples collected from (1) Inlet, (2) Outlet of M/S ST. JOHN'S ACADEMY, 54/VIII, CHURCH ROAD, JWALANAGAR, SHAHDARA, DELHI-110032 for drinking purpose.

Ref. No. SJN/DJB/01/25-26

Challan No: - 208,

dated: - 22.11.2025

ACWA-TYR

Diary No...736...dt.03.12.25

Date of collection: 24.11.2025

S. No.	PARTICULARS	BIS:10590-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A. Physical Examination						
1.	Colour	-	CLEAR	CLEAR
2.	Odour	-	CHLOR.	CHLOR.
3.	Turbidity	1.0	5.0	NTU	3.11	3.51
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	250	252
6.	Total Dissolved Solids	500	2000	mg/l	162	164
B. Chemical Examination						
7.	P th Alkalinity	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	84	86
9.	Total Hardness	200	600	mg/l	110	110
10.	Calcium as (Ca)	75	200	mg/l	30.4	29.6
11.	Magnesium as (Mg)	30	100	mg/l	8.16	8.64
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	3.32	3.40
15.	Sulphate	200	400	mg/l	32.00	33.15
16.	Chloride	250	1000	mg/l	12	12
17.	Fluoride	1.0	1.5	mg/l	0.05	0.04
18.	Dissolved Iron	1.0	NR	mg/l	0.10	0.12
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.75	0.50
C. Bacteriological Examination						
21.	Coliform count	Absent	NR	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform to the prescribed limits and can be considered fit for drinking purpose.

(B. Sheikh) / 26/11/25
ACWA(TYR)

Asstt. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tyr)
Tahir Pur Dilshad Garden, Delhi-93

(A.G Susmitha)
BACTERIOLOGIST

(Gulesh Jainar)
CHEMIST

(Mayank Yadav)
A/CHEMIST